



Product Service

Compliance Document

No. D 086470 0037 Rev. 00

Model(s):

Solis-1P4.6K-4G, Solis-1P4K-4G, Solis-1P3.6K-4G,
 Solis-P3K-4G, Solis-1P3K-4G-ST,
 URE-1P4.6K-4G, URE-1P4K-4G, URE-1P3.6K-4G,
 URE-1P3K-4G, URE-1P3K-4G-ST,
 GCI-1P4.6K-4G, GCI-1P4K-4G, GCI-1P3.6K-4G,
 GCI-1P3K-4G, GCI-1P3K-4G-ST,
 Mate-4.6K-4G, Mate-4K-4G, Mate-3.6K-4G,
 Mate-3K-4G, Mate-3K-4G-ST,
 Solis-1P2.5K-4G, Solis-1P2K-4G, Solis-1P1.5K-4G,
 Solis-1P1K-4G, URE-1P2.5K-4G,
 URE-1P2K-4G, URE-1P1.5K-4G, URE-1P1K-4G,
 GCI-1P2.5K-4G, GCI-1P2K-4G, GCI-1P1.5K-4G,
 GCI-1P1K-4G, Mate-2.5K-4G, Mate-2K-4G,
 Mate-1.5K-4G, Mate-1K-4G

Parameters:

Models	Solis-1P1K-4G GCI-1P1K-4G Mate-1K-4G URE-1P1K-4G	Solis-1P1.5K-4G GCI-1P1.5K-4G Mate-1.5K-4G URE-1P1.5K-4G	Solis-1P2K-4G GCI-1P2K-4G Mate-2K-4G URE-1P2K-4G	Solis-1P2.5K-4G GCI-1P2.5K-4G Mate-2.5K-4G URE-1P2.5K-4G
PV input ratings:				
Max. input voltage:	d.c. 550 V			
MPP voltage range:	d.c. 50 – 450V			
Max. input current:	d.c. 11A			
Isc PV (absolute maximum):	d.c. 17.2A			
AC output:				
Rated grid voltage:	a.c. 230/240V			
Rated grid frequency:	50/60Hz			
Max. AC output active power:	1100W	1700W	2200W	2800W
Max. AC output apparent power:	1100VA	1700VA	2200VA	2800VA
Max. Continuous output current:	a.c. 5.2A	a.c. 8.1A	a.c. 10.5A	a.c. 13.3A

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17



Product Service

Compliance Document

No. D 086470 0037 Rev. 00

F.3 Requirements for the test report for power generation units

Extract from test report for unit certificate "Determination of electrical properties"	No. 70.409.16.237.06-01	
Type of system	Grid-Tied Inverter for PV system	Manufacturer's data
Generation unit manufacturer	Ningbo Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA	Type of system: Grid-tied Inverter for PV system
		Active power (nominal power at reference conditions): 4600W (Solis-1P4.6K-4G), 4400W (Solis-1P4K-4G), 4000W (Solis-3.6K-4G), 3300W (Solis-1P3K-4G, Solis-1P3K-4G-ST)
		Rated voltage: 230 V ~
Period of measurement: From 2017-03-21 – 2017-04-16, 2017-06-09 - 2017-06-11		

Active power	4600W (Solis-1P4.6K-4G), 4400W (Solis-1P4K-4G), 4000W (Solis-3.6K-4G), P _{Emax} 3300W (Solis-1P3K-4G, Solis-1P3K-4G-ST)
--------------	---

Reactive power reference (0.91Un) (Solis-1P4.6K-4G)										
Active power P/P _n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible cosφ _{under-excited}	0.804	0.809	0.803	0.807	0.808	0.807	0.807	0.806	0.903 **	0.999 **
Max. possible cosφ _{over-excited}	0.808	0.808	0.808	0.806	0.805	0.804	0.804	0.803	0.901 **	0.999 **

Reactive power reference (Un) (Solis-1P4.6K-4G)										
Active power P/P _n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible cosφ _{under-excited}	0.839	0.803	0.803	0.802	0.805	0.804	0.802	0.803	0.901 **	0.999 **
Max. possible cosφ _{over-excited}	0.799	0.802	0.802	0.805	0.804	0.803	0.803	0.803	0.901 **	0.999 **

Reactive power reference (1.09Un) (Solis-1P4.6K-4G)										
Active power P/P _n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible cosφ _{under-excited}	0.802	0.799	0.801	0.800	0.801	0.801	0.803	0.804	0.801	0.999 **
Max. possible cosφ _{over-excited}	0.802	0.802	0.801	0.801	0.800	0.800	0.800	0.799	0.801	0.999 **

Remark: "**": When test at 0.91Un, together with the max. current is limited by software and the apparent power is limited accordingly, and when fixed P to 100%P_n, the default cosφ is limited as well.
 "***" Due to apparent power is limited, the maximum active power is reduced accordingly. The active power 100% P/P_n is therefore not achieved to default cos φ.

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17



Product Service

Compliance Document

No. D 086470 0037 Rev. 00

Reactive power reference (0.91Un) (Solis-1P1K-4G)										
Active power P/P_n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible $\cos\phi_{\text{under-excited}}$	0.804	0.809	0.803	0.807	0.808	0.807	0.807	0.806	0.903 *	0.999 **
Max. possible $\cos\phi_{\text{over-excited}}$	0.808	0.808	0.808	0.806	0.805	0.804	0.804	0.803	0.901 *	0.999 **

Reactive power reference (Un) (Solis-1P1K-4G)										
Active power P/P_n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible $\cos\phi_{\text{under-excited}}$	0.839	0.803	0.803	0.802	0.805	0.804	0.802	0.803	0.901 *	0.999 **
Max. possible $\cos\phi_{\text{over-excited}}$	0.799	0.802	0.802	0.805	0.804	0.803	0.803	0.803	0.901 *	0.999 **

Reactive power reference (1.09Un) (Solis-1P1K-4G)										
Active power P/P_n [%]	10	20	30	40	50	60	70	80	90	100
Max. possible $\cos\phi_{\text{under-excited}}$	0.802	0.799	0.801	0.800	0.801	0.801	0.803	0.804	0.801	0.999 **
Max. possible $\cos\phi_{\text{over-excited}}$	0.802	0.802	0.801	0.801	0.800	0.800	0.800	0.799	0.801	0.999 **

Remark: "*" : When test at 0.91Un, together with the max. current is limited by software and the apparent power is limited accordingly, and when fixed P to 100%Pn, the default $\cos\phi$ is limited as well.
 "***" Due to apparent power is limited, the maximum active power is reduced accordingly. The active power 100% P/Pn is therefore not achieved to default $\cos\phi$.

Compliance of required displacement factor $\cos\phi$ (Solis-1P4.6K-4G)											
Default in system control	0.900 _o v	0.920 _o v	0.940 _o v	0.960 _o v	0.980 _o v	1.000	0.980 _u n	0.960 _u n	0.940 _u n	0.920 _u n	0.900 _{un}
Measured value at PGU terminals @0.91Un	0.900	0.920	0.940	0.960	0.979	0.999	0.980	0.961	0.942	0.922	0.902
Measured value at PGU terminals @Un	0.899	0.919	0.939	0.958	0.979	0.999	0.981	0.962	0.942	0.923	0.904
Measured value at PGU terminals @1.09Un	0.897	0.917	0.937	0.957	0.978	0.999	0.982	0.963	0.943	0.923	0.904



Product Service

Compliance Document

No. D 086470 0037 Rev. 00

Compliance of required displacement factor $\cos\phi$ (Solis-1P1K-4G)											
Default in system control	0.900 _o	0.920 _o	0.940 _o	0.960 _o	0.980 _o	1.000	0.980 _u	0.960 _u	0.940 _u	0.920 _u	0.900 _{un}
Measured value at PGU terminals @0.91Un	0.900	0.920	0.940	0.960	0.979	0.999	0.980	0.961	0.942	0.922	0.902
Measured value at PGU terminals @Un	0.899	0.919	0.939	0.958	0.979	0.999	0.981	0.962	0.942	0.923	0.904
Measured value at PGU terminals @1.09Un	0.897	0.917	0.937	0.957	0.978	0.999	0.982	0.963	0.943	0.923	0.904

Reactive power transfer function – Standard- $\cos\phi$ -(P)-characteristic (Solis-60K-4G)										
Active power P/P_n [%]	10	20	30	40	50	60	70	80	90	100
$\cos\phi$	--	0.995	0.997	0.998	0.999	0.977	0.957	0.936	0.916	-*

Conform to Standard- $\cos\phi$ -(P)-characteristic
 * The maximum apparent power of the inverter is limited to SEmax. If setting $\cos\phi \neq 1$, the maximum active power is reduced accordingly. The active power 100% P/PEmax is therefore only achieved when $\cos\phi = 1$.

Switching actions		
Making operation without default (of primary energy carrier)	k_i	0.138
Worst case at switch over of generator sections	k_i	--
Making operation at reference conditions (of primary energy carrier)	k_i	1.098
Breaking operation at nominal power	k_i	1.188
Worst-case value of all switching operations	k_{imax}	1.188

Flicker	Angle of network impedance ψ_k :	32° ¹⁾	50°	70°	85°
Solis-1P4.6K-4G	Coefficient of system flicker c_{ψ} :	5.65	-	-	-
Solis-1P3.6K-4G	Coefficient of system flicker c_{ψ} :	7.98			

Remark: ¹⁾ $R_A = 0.24 \Omega$; $X_A = j 0.15 \Omega$ at 50 Hz network impedance used for most unfavorable condition which is approximately 32° flicker angle.

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認 證 證 書 ◆ CERTIFICADO ◆ CERTIFICAT

A4 / 07.17



Product Service

Compliance Document

No. D 086470 0037 Rev. 00

Harmonics (Solis-1P1K-2G)											
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100
Ordinal number	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]
2	--	0.251	0.224	0.203	0.202	0.199	0.196	0.193	0.204	0.194	0.216
3	--	0.767	0.718	0.714	0.720	0.754	0.802	0.881	0.955	1.083	0.614
4	--	0.097	0.095	0.100	0.117	0.128	0.135	0.133	0.158	0.195	0.161
5	--	0.053	0.443	0.578	0.615	0.627	0.643	0.639	0.660	0.685	0.756
6	--	0.185	0.199	0.203	0.185	0.174	0.166	0.164	0.168	0.173	0.114
7	--	0.375	0.375	0.561	0.614	0.617	0.651	0.635	0.635	0.648	0.656
8	--	0.100	0.040	0.071	0.083	0.082	0.078	0.085	0.088	0.105	0.054
9	--	0.241	0.205	0.374	0.439	0.459	0.472	0.496	0.497	0.496	0.482
10	--	0.073	0.062	0.049	0.054	0.062	0.061	0.063	0.054	0.067	0.075
11	--	0.237	0.226	0.370	0.417	0.452	0.468	0.480	0.481	0.474	0.443
12	--	0.045	0.099	0.067	0.091	0.095	0.090	0.091	0.095	0.113	0.043
13	--	0.184	0.229	0.183	0.109	0.070	0.077	0.065	0.076	0.087	0.133
14	--	0.082	0.068	0.098	0.103	0.093	0.087	0.095	0.094	0.102	0.038
15	--	0.035	0.051	0.082	0.114	0.154	0.184	0.206	0.198	0.210	0.244
16	--	0.077	0.070	0.057	0.047	0.054	0.055	0.061	0.064	0.078	0.071
17	--	0.103	0.142	0.118	0.112	0.121	0.156	0.176	0.186	0.194	0.227
18	--	0.059	0.063	0.039	0.064	0.050	0.050	0.048	0.060	0.073	0.068
19	--	0.062	0.039	0.043	0.100	0.154	0.221	0.273	0.283	0.320	0.392
20	--	0.027	0.054	0.038	0.056	0.061	0.064	0.053	0.055	0.065	0.059
21	--	0.091	0.104	0.082	0.133	0.146	0.167	0.191	0.205	0.231	0.269
22	--	0.095	0.083	0.113	0.109	0.093	0.097	0.109	0.110	0.116	0.122
23	--	0.067	0.057	0.062	0.086	0.081	0.103	0.093	0.122	0.164	0.251
24	--	0.052	0.048	0.057	0.062	0.074	0.092	0.116	0.110	0.106	0.076
25	--	0.120	0.121	0.132	0.112	0.111	0.111	0.085	0.088	0.092	0.201
26	--	0.039	0.036	0.054	0.045	0.044	0.048	0.046	0.034	0.043	0.137
27	--	0.082	0.106	0.116	0.115	0.132	0.167	0.192	0.217	0.244	0.301
28	--	0.043	0.050	0.040	0.052	0.056	0.051	0.033	0.021	0.048	0.122
29	--	0.133	0.143	0.101	0.078	0.067	0.073	0.084	0.120	0.133	0.199
30	--	0.037	0.048	0.054	0.040	0.046	0.053	0.043	0.055	0.060	0.104
31	--	0.100	0.132	0.124	0.129	0.129	0.123	0.135	0.126	0.135	0.235
32	--	0.050	0.040	0.038	0.055	0.051	0.041	0.027	0.028	0.038	0.210
33	--	0.078	0.096	0.117	0.099	0.095	0.117	0.097	0.104	0.123	0.251
34	--	0.026	0.028	0.039	0.038	0.036	0.034	0.034	0.030	0.041	0.158
35	--	0.132	0.137	0.122	0.074	0.061	0.086	0.116	0.130	0.137	0.226
36	--	0.031	0.035	0.033	0.032	0.024	0.044	0.050	0.058	0.064	0.061
37	--	0.092	0.165	0.189	0.169	0.171	0.167	0.126	0.110	0.088	0.240
38	--	0.045	0.036	0.049	0.078	0.062	0.067	0.063	0.064	0.066	0.104
39	--	0.127	0.123	0.128	0.128	0.109	0.125	0.137	0.150	0.179	0.335
40	--	0.053	0.039	0.034	0.040	0.032	0.039	0.045	0.041	0.045	0.103

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT



A4 / 07.17

