

C E R T I F I C A T E
of Conformity



Registration No.: AK 50508635 0001

Report No.: CN21XXBR 001

Holder: **Ginlong technologies Co., Ltd.**
No.57 Jintong Road, Binhai,
(seafront), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Product: PV-Inverter
(Grid-Connected PV Inverter)

Identification: Type Designation : Solis-80K-5G Solis-100K-5G
Solis-110K-5G
S5-GC80K S5-GC100K S5-GC110K
Serial Number : Engineering Samples
Firmware version : 21
Remark(s) : Refer to report CN21XXBR 001 for details.

Tested acc. to: CEI 0-16:2019

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.



Date 12.07.2021


Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

OGGETTO: Dichiarazione di conformità alla normativa CEI 0-16:2019
 "Regola tecnica di riferimento per la connessione di Utenti attivi e passivi
 alle reti AT ed MT delle imprese distributrici di energia elettrica"



SUBJECT: Declaration of Conformity to CEI 0-16:2019
 "Reference technical rules for the connection of active and passive consumers to
 the HV and MV electrical networks of distribution Company"

Certificate No.: AK 50508635 0001

TIPOLOGIA DI APPARATO A CUI SI RIFERISCE LA DICHIARAZIONE:
 TYPE OF APPARATUS WHICH THE DECLARATION IS REFERED TO:

GENERATORI SINCRONI Synchronous generators	GENERATORI ASINCRONI Asynchronous generators	GENERATORI STATICI FV Static generators PV	GENERATORI EOLICI FULL CONVERTER Full Power Wind Generators
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Costruttore
Manufacturer

Ginlong technologies Co., Ltd.
 No.57 Jintong Road, Binhai, (seafont) industrial Park, Xiangshan, Ningbo, zhejiang,
 315712, P.R. China

Modello/Tipo
Model/Type

Solis-80K-5G	Solis-100K-5G	Solis-110K-5G	S5-GC80K	S5-GC100K	S5-GC110K
80	100	110	80	100	110
88	110	121	88	110	121

Firmware release
Firmware

21

Numero di Fasi
Number of phases
Informazioni sulla batteria
Battery information

Trifase/ Three-phase
N/A

Note
Remarks

Il dispositivo è in grado di limitare la Idc allo 0,5% della corrente nominale.
The device is capable to limit the Idc to 0,5% of the nominal current.

laboratorio di prova
Test laboratory

TÜV Rheinland (Shanghai) Co., Ltd.
 Accreditation CNAS no.: L3038

Esaminati I Fascicoli Prove N.: CN21XXBR 001 emesso da TÜV Rheinland (Shanghai) S.r.l.
 Having assessed the Test Files N. CN21XXBR 001 issued by TÜV Rheinland (Shanghai) Co., Ltd.

Si dichiara che i prodotti indicati soddisfano i requisiti della CEI 0-16:2019 "Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti AT ed MT delle imprese distributrici di energia elettrica"
 We declare that the products indicated meet the requirements laid down by CEI 0-16:2019 "Reference technical rules for the connection of active and passive consumers to the HV and MV electrical networks of distribution Company"

Validità della
Dichiarazione
Validity of the
Declaration

Questa Dichiarazione è valida per i prodotti indicate, così come descritti nei Fascicoli citati. Nuovi requisiti o emendamenti a requisiti esistenti, così come modifiche al prodotto, possono implicare nuove verifiche e certificazioni.
 This Declaration is valid only for the products indicated herein, as described in the Files mentioned. New requirements or amendment to existing ones, or modifications to the product, may imply re-verification and re-certification.

TÜV Rheinland (China) Ltd.
Member of TÜV Rheinland Group



Ginlong technologies Co., Ltd.
Zhang Kun

Date : 12.07.2021
Our ref. : HCC 01
Your ref.: Kun Zhang

No.57 Jintong Road, Binhai,
(seafont), Industrial Park,
Xiangshan Ningbo
315712 Zhejiang
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-Connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50508635 0001
Report No. : CN21XXBR 001

Dear Zhang Kun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Weichun Li

CC: Ginlong technologies Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

TÜV Rheinland (China) Ltd.
莱茵检测认证服务(中国)有限公司

Unit 707, AVIC Bldg., No. 10B,
Central Road, East 3rd Ring
Road, Chaoyang District,
Beijing, 100022, P.R.China

北京市朝阳区东三环中路乙10号
艾维克大厦707室
邮编: 100022

Tel: (8610)6566 6660
Fax: (8610)6566 6667
e-mail: info@bj.chn.tuv.com
Internet: <http://www.chn.tuv.com>