

Compliance Document

No. D 086470 0108 Rev. 01

Holder of Certificate: **Ginlong Technologies Co., Ltd.**

No.57 Jintong Road
Binhai Industrial Park, Xiangshan
315712 Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA


Product:

Converter
Grid-interactive inverter with storage
battery system

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092103621-01

Date, 2022-11-25



(Zhengdong Ma)

Compliance Document

No. D 086470 0108 Rev. 01

Model(s):

Gird-interactive inverter: RHI-3K-48ES-5G, RHI-3K-48ES-5G-NS,
 5G-NS,
 5G-NS,
 NS,
 NS,
 EH1P4.6K-L,
 EH1P3K-L-NS,
 NS,
 NS,
 NS,
 S5-EH1P3K-L, S5-EH1P3.6K-L, S5-EH1P5K-L, S5-EH1P6K-L, S5-EH1P3.6K-L-NS, S5-EH1P4K-L-NS, S5-EH1P4.6K-L-NS, S5-EH1P5K-L-NS,
Storage battery system: US5000, US5000-B

Parameters:

The following generators meet the requirements of CEI 0-21:2022	
Manufacturer	Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA
Equipment type	Grid-interactive inverter with storage battery system
Brand	Solis
Number of phase	<input checked="" type="checkbox"/> Single phase <input type="checkbox"/> Three phase Frequency: 50Hz Voltage: a.c. 230V
Primary energy used	<input checked="" type="checkbox"/> Solar <input checked="" type="checkbox"/> Storage <input type="checkbox"/> Wind <input type="checkbox"/> Hydroelectric <input type="checkbox"/> CHP <input type="checkbox"/> Other: Note: RAI-3K-48ES-5G can be operated with battery input only, other models can be operated with both PV and battery inputs.
Section A	Generator model
	Rated power

RHI-3K-48ES-5G, RHI-3K-48ES-5G-NS, S5-EH1P3K-L, RAI-3K-48ES-5G, S5-EH1P3K-L-NS	RHI-3.6K-48ES-5G, RHI-3.6K-48ES-5G-NS, RHI-4K-48ES-5G-NS, S5-EH1P4.6K-L, S5-EH1P3.6K-L-NS, S5-EH1P3.6K-L-NS, S5-EH1P4K-L-NS	RHI-4.6K-48ES-5G, RHI-4.6K-48ES-5G-NS, S5-EH1P4.6K-L, S5-EH1P4.6K-L-NS	RHI-5K-48ES-5G, RHI-5K-48ES-5G-NS, S5-EH1P5K-L, S5-EH1P5K-L-NS	RHI-6K-48ES-5G, RHI-6K-48ES-5G-NS, S5-EH1P6K-L, S5-EH1P6K-L-NS
3000 W / 3300 VA	3600 W / 4000 VA	4600 W / 4600 VA	5000 W / 5500 VA	6000 W / 6600 VA

Compliance Document

No. D 086470 0108 Rev. 01

	The generator:	<input type="checkbox"/> is suitable for installation in systems with an output power of more than 11.08 kW <input checked="" type="checkbox"/> is capable of limiting I _{dc} to 0.5% of rated current: <input checked="" type="checkbox"/> uses a DC-sensitive protection function <input type="checkbox"/> uses a transformer operating at mains frequency
--	----------------	--

Section B	Characteristics of the interface protection system					
	Manufacturer	Ginlong Technologies Co., Ltd.				
	Model	RHI-3K-48ES-5G, RHI-3K-48ES-5G-NS, RAI-3K-48ES-5G, RHI-3.6K-48ES-5G, RHI-3.6K-48ES-5G-NS, RHI-4K-48ES-5G-NS, RHI-4.6K-48ES-5G, RHI-4.6K-48ES-5G-NS, RHI-5K-48ES-5G, RHI-5K-48ES-5G-NS, RHI-6K-48ES-5G, RHI-6K-48ES-5G-NS, S5-EH1P3K-L, S5-EH1P3.6K-L, S5-EH1P4.6K-L, S5-EH1P5K-L, S5-EH1P6K-L, S5-EH1P3K-L-NS, S5-EH1P3.6K-L-NS, S5-EH1P4K-L-NS, S5-EH1P4.6K-L-NS, S5-EH1P5K-L-NS, S5-EH1P6K-L-NS				
	Type	<input checked="" type="checkbox"/> Integrated <input type="checkbox"/> Not integrated				
Section C	Characteristics of inverter(s)					
	Model of inverter	RHI-3K-48ES-5G, RHI-3K-48ES-5G-NS, S5-EH1P3K-L, RAI-3K-48ES-5G, S5-EH1P3K-L-NS	RHI-3.6K-48ES-5G, RHI-3.6K-48ES-5G-NS, RHI-4K-48ES-5G-NS, S5-EH1P3.6K-L, S5-EH1P3.6K-L-NS, S5-EH1P4K-L-NS	RHI-4.6K-48ES-5G, RHI-4.6K-48ES-5G-NS, S5-EH1P4.6K-L, S5-EH1P4.6K-L-NS	RHI-5K-48ES-5G, RHI-5K-48ES-5G-NS, S5-EH1P5K-L, S5-EH1P5K-L-NS	RHI-6K-48ES-5G, RHI-6K-48ES-5G-NS, S5-EH1P6K-L, S5-EH1P6K-L-NS
	Manufacturer of inverter	Ginlong Technologies Co., Ltd.				
	Firmware version	A1				
	Rated power of inverter (P _{NINV})	3000 W	3600 W	4600 W	5000 W	6000 W

Compliance Document

No. D 086470 0108 Rev. 01

Characteristics of the Storage System (SdA)								
Section E	Representative Combination	RHI-3K-48ES-5G, RHI-3K-48ES-5G-NS, RAI-3K-48ES-5G, S5-EH1P3K-L, S5-EH1P3K-L-NS with US5000 or US5000-B (1-16 pieces)	RHI-3.6K-48ES-5G, RHI-3.6K-48ES-5G-NS, S5-EH1P3.6K-L, S5-EH1P3.6K-L-NS, RHI-4K-48ES-5G-NS, S5-EH1P4K-L-NS with US5000 or US5000-B (1-16 pieces)	RHI-XK-48ES-5G, RHI-XK-48ES-5G-NS, S5-EH1PXX-L, S5-EH1PXX-L-NS(X=4.6, 5, 6) with US5000 or US5000-B (1 piece)	RHI-4.6K-48ES-5G, RHI-4.6K-48ES-5G-NS, S5-EH1P4.6K-L, S5-EH1P4.6K-L-NS with US5000 or US5000-B (2-16 pieces)	RHI-5K-48ES-5G, RHI-5K-48ES-5G-NS, S5-EH1P5K-L, S5-EH1P5K-L-NS with US5000 or US5000-B (2-16 pieces)	RHI-6K-48ES-5G, RHI-6K-48ES-5G-NS, S5-EH1P6K-L, S5-EH1P6K-L-NS with US5000 or US5000-B (2-16 pieces)	
	Psn (nominal discharge power)	3000	3000	3400	4500	4500	4500	
	Pcn (nominal charging power)	3000	3600	4200	4600	5000	6000	
	Psmax (max. discharge power)	3000	3000	3400	4500	4500	4500	
	Pcmax (max. charging power)	3000	3600	4200	4600	5000	6000	
	Type	<input checked="" type="checkbox"/> Bidirectional <input type="checkbox"/> Monodirectional						
	Batteries that can be used with the above static converters							
	Brand	Pylon						
	Technology	Li-Ion						
	Models	US5000, US5000-B						
CUS module (kWh)	4.8							
BMS firmware version	US5000_MMCB_U150							
Number of modules	1-16							
Note	Batteries are not contained in the inverter and should be installed according to local regulations and in accordance with Pylon instruction.							

Compliance Document

No. D 086470 0108 Rev. 01

Section I	References of the laboratories that performed the tests and their test reports (RdP)		
	Selected method	<input checked="" type="checkbox"/> Tests performed under the supervision of a certification body	<input checked="" type="checkbox"/> Tests performed by an accredited laboratory
	Test Reports (RdP)	1) Test report according to Annex A, Annex B & Bbis: 70.409.20.081.14-00, 70.409.21.036.20-00 and 70.409.21.036.21-01	2) Test report EMC: a) C19-447-WT-01; b) C19-447-WT-02; c) 64772228001902
	Issued by	Testing lab: 1) Ginlong Technologies Co., Ltd. Tests performed under supervision of certifier from TÜV SÜD Product Service GmbH	2) -a) & -b) Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co.,Ltd. 2) -c) TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch
	Accreditation No.	D-ZE-11321-01-00	2) -a) & b) CNAS L0130 2) -c) CNAS L3584
	Accreditation body ref.	DAKKS	CNAS
Section M	Reference of the certification body		
	Certification Body	TÜV SÜD Product Service GmbH DAKKS accreditation certificate D-ZE-11321-01-00 according to DIN EN ISO/IEC 17065:2013	

Tested according to:

CEI 0-21:2022