



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC18024197906

NAME AND ADDRESS OF THE APPLICANT

Ningbo Ginlong Technologies Co., Ltd.
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Ningbo Ginlong Technologies Co., Ltd.
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

NAME AND ADDRESS OF THE FACTORY

Ningbo Ginlong Technologies Co., Ltd. (V017008)
No.57, Jintong Road, Binhai industrial park, Xiangshan, Ningbo, Zhejiang, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

PV Grid-connected Inverter
GCI-3P5K-4G, GCI-3P6K-4G, GCI-3P8K-4G, GCI-3P9K-4G, GCI-3P10K-4G (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2018

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018 .

Valid from: Jun.26,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Jul.10,2018



President: _____

A handwritten signature in black ink, appearing to be "Lu Mei", written over a horizontal line.

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



太阳能产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC18024197906

纸 号:

GCI-3P5K-4G

直流输入: MPPT 电压范围 160V-850Vdc, 最大直流输入电压 1000Vdc, 最大输入电流 11A+11A; 交流输出: 3/N/PE~, 220V/380V, 50Hz, Max. 8.4A, 额定交流输出功率 5kW;

GCI-3P6K-4G

直流输入: MPPT 电压范围 160V-850Vdc, 最大直流输入电压 1000Vdc, 最大输入电流 11A+11A; 交流输出: 3/N/PE~, 220V/380V, 50Hz, Max. 10A, 额定交流输出功率 6kW;

GCI-3P8K-4G

直流输入: MPPT 电压范围 160V-850Vdc, 最大直流输入电压 1000Vdc, 最大输入电流 11A+11A; 交流输出: 3/N/PE~, 220V/380V, 50Hz, Max. 13.4A, 额定交流输出功率 8kW;

GCI-3P9K-4G

直流输入: MPPT 电压范围 160V-850Vdc, 最大直流输入电压 1000Vdc, 最大输入电流 11A+11A; 交流输出: 3/N/PE~, 220V/380V, 50Hz, Max. 15.1A, 额定交流输出功率 9kW;

GCI-3P10K-4G

直流输入: MPPT 电压范围 160V-850Vdc, 最大直流输入电压 1000Vdc, 最大输入电流 11A+11A; 交流输出: 3/N/PE~, 220V/380V, 50Hz, Max. 16.7A, 额定交流输出功率 10kW.

注: 此附录与证书同时使用时有效。



主任: _____

陆梅

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>